

## **SAS Superstructure**

Location: 04-SF-80-13.2 / 13.9 Client Name: CalTrans 
 Run date
 19-Nov-14

 Time
 4:16 PM

04-0120F4

04-SF-80-13.2/13.9

Self-Anchored

**Suspension Bridge** 

## Daily Diary Report by Bid Item

Contract No.: 04-0120F4

Diary #: 042 Const Calendar Day: 219 Date: 15-Apr-2010 Thursday Inspector Name: Altamirano, Victor Title: Transportation Engineer

Inspection Type:

Shift Hours: Break: Over Time:

Federal ID: Location:

Reviewer: Lai, Gary Approved Date: 03-May-10 Status: Approved

Weather

**Temperature 7 AM** 50 - 60 **12 PM** 50 - 60 **4PM** 50 - 60

Precipitation Condition

Working Day **V** If no, explain:

Diary: Dispute

## Work description.

Field Work:

I conducted NO field work today.

Office Work:

- 1. Reviewed the redlines from PB and DJV for submittal's 915R1 and R2. A unistrut on the left side of the diaphram plate detailed on section k-k of sheet W5-SB8 is needed. DJV aware of this and this sheet will be revised.
- 2. Attended CRM regarding the submittal's 915R1 and R2. Notes of CRM will be provided in tomorrow's diary.

Hours Worked: 10 hours total, including 2 hours overtime.